

Rejoinder

The news published in **Daily Desher Katha** on 24th July 2021 at page – 01 regarding power cut in GB Hospital has come to the notice of Tripura State Electricity Corporation (TSECL). In this regard, it is clarified that –

On 21.07.2021 11 KV AGMC Feeder was in running condition throughout the day as per record of Grid Sub-station, 79 tilla, Agartala. As per information gathered from GBP Hospital Authority due to occurrence of disturbance in 01 (One) incomer breaker at their control room (That is maintained by Hospital Authority) power supply was not catered in hospital premises on that period. After rectification of that breaker, power supply has been restored.

GB Hospital is a bulk consumer of TSECL. They take power from TSECL at 11 KV level. They have their own LT system along with distribution transformers. LT system is completely maintained by them. TSECL has no right to interfere there as per law. There was no problem in the 11 KV side (TSECL's portion). As such, allegation on TSECL in this incident is completely baseless.

Therefore, the facts are required to publish in the concerned newspaper as rejoinder against the said news.